

Approval Number 2211528
Test Report: J-00436732 & J-00436733



28th November 2022

Mahalaxmi Rubber Products
Plot No 58,
Phase 1,
IDA Cherlapally,
Hyderabad, 500051,
India

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS- ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.

5365

'MRP-EN-50, MRP-EN-55, MRP-EN-60, MRP-EN-65, MRP-EN-70, MRP-EN-75 & MRP-EN-80'.

Black coloured, compression moulded EPDM materials with a shore hardness of between 50 & 80. Tested in-radius size 0.88mm. For use with water up to 65°C.

APPROVAL NUMBER: 2211528

APPROVAL HOLDER: MAHALAXMI RUBBER PRODUCTS

The Scheme reserves the right to review approval.
Approval 2211528 is valid between November 2022 and November 2027

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager